



THE MIDNAPORE CO-OP MILK PRODUCERS' UNION LTD.

(An Operation Flood Project, Government of West Bengal)

Ashok Nagar: Midnapore -721101: Paschim Medinipur

Phone (03222) 275697; Email: office.mimul@gmail.com

Ref: MU/e-Tender/24-25/ 646

Date: 07/02/2025

Corrigendum

NIT No- MU/e-Tender/03/24-25/615 Dated-24/01/2025

Tender ID: 2025_ARD_806524_1

The Midnapore Milk Union is to Notify the CORRIGENDUM to the NIT document of the e-tender under reference for the work “**Design, Manufacture, Supply, Erection, Testing and Commissioning of Solar Photovoltaic (PV) System with Civil Works & Accessories at The Milk Processing Unit, Dude-Budhe, Keshiary, District Paschim Medinipur, West Bengal**” as under:

KINDLY READ AS:-

In NIT:

Sl. No. 14 – Date and Time Schedule:

(i) Pre-Bid Meeting and Demonstration : Mandatory
(Attending of Pre-Bid Meeting is Mandatory to participate in the Tender)

Second (2nd) Meeting Scheduled on: 17.02.2025 at 11:30 AM at the Head Quarter, Midnapore Milk Union, Ashoknagar, Midnapore, Paschim Medinipur, PIN-721101.

Note: The Bidders who have attended the First (1st) Pre-Bid Meeting and Demonstration held on 07.02.2025 may or may not attend the second Pre-Bid Meeting.

(ii) Bid Submission Closing Date (Online) : 21.02.2025 upto 6:00 PM

(iii) Bid Opening date for Technical : 24.02.2025 at 11:00 AM onwards
Proposals (Online)



INSTEAD OF:-

Sl. No. 14 – Date and Time Schedule:

- (i) Pre-Bid Meeting and Demonstration : 06.02.2025 at 11:30 AM
(ii) Bid Submission Closing Date (Online) : 14.02.2025 upto 6:00 PM
(iii) Bid Opening date for Technical Proposals (Online) : 17.02.2025 at 11:00 AM onwards

KINDLY READ AS:-

CHECK-LIST (Information about Bidders)

Serial	Description	Particulars	Page No.
12	List of Drawings (Equipment GA, Layout, service schematics etc as per 7.0 A of Technical Specification)		

INSTEAD OF:-

CHECK-LIST (Information about Bidders)

Serial	Description	Particulars	Page No.
12	List of Drawings (Equipment GA, Layout, service schematics etc as per 3.0, 7.0 A, 8.0 of Technical Specification)		

In Annexure-I

KINDLY READ AS:-

SOLAR PHOTOVOLTAIC:

4.1.1 SOLAR PV Module:

S. No.	Parameter	Requirement	Remarks
2.	Module Capacity Rating (Pmax)	Minimum 550Wp	144 cells per module



INSTEAD OF:-

SOLAR PHOTOVOLTAIC:

4.1.1 SOLAR PV Module:

S. No.	Parameter	Requirement	Remarks
2.	Module Capacity Rating (Pmax)	Minimum 550Wp	72 cells per module

KINDLY READ AS:-

4.2. EARTHING PROTECTION:

GI flat 32 X 6mm required between each string and string to earth electrode.

GI Earth Plate of 600 x 600 x 6mm with 2mtr x 48mm B Class GI Pipe and MS Strip Hot dip Galvanized thickness 110 micron fitted with clamp, funnels, etc. And required adequate quantity of earthing chemicals with civil works to secure the earthing.

Earthing: Bidder should install and provide all inputs / material for proper earthing as per IS Code / Local Electricity Board Regulation. The scope of work includes excavation for earth pit, construction of chamber, filling with necessary materials and complete with cover.


INSTEAD OF:-

4.2. EARTHING PROTECTION:

Copper flat 25 X 3mm required between each string and string to earth electrode.

Pipe-in-pipe type Copper earthing electrode(chemical earth) shall be used - Minimum 2 nos/as per Standard required with earthing chamber, cover etc. as per above specifications.

REST OF THE TERMS AND CONDITIONS SHALL REMAIN UNCHANGED.


Managing Director
Midnapore Milk Union